

# *Renewable Energy Analysis: Geospatial Analysis and Maps (U.S.)*

Andy Walker, Ph.D., PE

Donna Heimiller

National Renewable Energy Laboratory

Energy Master Planning for Resilient Public Communities –

Virtual Training Workshop

October 13-16, 2020

<https://www.nationalacademies.org/energy-master-planning-2020>

PR-77938

# Federal Energy Management Program (FEMP) Renewable Energy Geospatial Map Tool

<http://maps.nrel.gov/femp>



- Coverage: Continental United States, Alaska, and Hawaii
- High-level, annualized economic calculation:
  - Economic calculations for photovoltaics (PV), wind, solar water heating, solar vent air preheat
  - Economic results: savings-to-investment ratio, payback period, levelized cost of energy
  - Discount rates and escalation rates compliant with 10CFR436
  - With and without potential savings from available renewable energy incentives at the state and federal level
  - Other layers that might be relevant to planning renewable energy projects, such as:
    - Renewable energy resource data (hydropower, geothermal, biomass)
    - Land ownership
    - Environmentally sensitive areas
    - Topographical relief.


# Technology Configurations



Reciprocating engine combined heat and power (CHP)  
Reciprocating CHP with seasonal storage




Combustion turbine CHP  
Combustion turbine CHP with seasonal storage




PV + 0-hour battery  
PV + 4-hour battery  
PV + 12-hour battery



Concentrating solar power (CSP) + 0-hour storage (TES)  
CSP + 4-hour TES  
CSP + 12-hour TES



Wind + 0-hour battery  
Wind + 4-hour battery  
Wind + 12-hour battery



Solar water heating (SWH) with diurnal storage  
SWH with seasonal storage


# Annual Energy Delivery and Capacity Factor

$$E = P_{rated} * CF * T$$
$$CF = \frac{E}{TP_{rated}}$$
$$P_{rated} = \frac{E}{CF T}$$

*Definitions of  $P_{rated}$  and CF must be consistent with each other.*

- E = annual energy delivery (kWh/yr) of the systems
- CF = capacity factor, energy delivery (kWh/yr) divided by rated power,  $P_{rated}$  (kW), and divided by total time period, T (h); percentage of time a system delivers its rated capacity
- Capacity factor includes balance-of-system losses (AC capacity factor).

# Storage extends Capacity Factor of a Rated Power



$CF$  = capacity factor based on resource availability

$$CF' = CF + t/T$$

$T$  = hours of storage (that the power level,  $P_{\text{rated}}$ , might be extended)

$T$  = time period over which resource  $CF$  is defined ( $T = 24 \text{ hr/day}$  or  $8760 \text{ h/year}$ )

$$P_{\text{install}} = P_{\text{rated}} (1 + t / (CF * T)) / \eta_{\text{storage}}$$

# Initial and Annual Operating Costs of each Technology Configuration

## Initial cost:

$$C_{\text{initial}} = C_{\text{initial fixed}} + C_{\text{gen unit}} * P_{\text{install}} + C_{\text{storage unit}} * t * P_{\text{rated}}$$

$C_{\text{initial fixed}}$  = fixed project development costs (\$)

$C_{\text{gen unit}}$  = unit cost per kW of installed capacity (\$/kW)

$C_{\text{storage unit}}$  = unit cost per kWh cost of storage technology (battery) (\$/kWh)

$C_{\text{storage unit seasonal}}$  = unit cost per kWh cost of seasonal thermal storage (pit storage) (\$/kWh)

## Operation-and-maintenance (O&M) cost:

$$C_{\text{OM}} = C_{\text{fixed O\&M}} + P_{\text{installed}} * C_{\text{gen O\&M}} + C_{\text{storage O\&M}} * t * P_{\text{rated}}$$

$C_{\text{fixed O\&M}}$  = fixed O&M cost independent of size

$C_{\text{gen O\&M}}$  = unit O&M cost per kW of installed generation capacity (\$/kW)

$C_{\text{storage O\&M}}$  = unit O&M cost per kWh cost of storage technology (battery) (\$/kWh), or for seasonal thermal storage technology (pit storage) (\$/kWh-thermal)

# Fuel Use and Heat Recovery for Combined Heat and Power

- The general approach includes fuel use, such as natural gas or biomass fuel. The amount of fuel used per year is:

$$F = P_{\text{installed}} * (CF * 8760 / \eta_{\text{elec}}) [1 - (1 - \eta_{\text{elec}}) \text{HRF} / \eta_{\text{conv}}]$$

- F = fuel used per year to provide rated electric generation (kWh/yr)
- $\eta_{\text{elec}}$  = efficiency of electric generator; reciprocating engine  $\eta_{\text{elec}} = 0.34$ , combustion turbine  $\eta_{\text{elec}} = 0.25$
- Conversion factor of 3412 Btu/kWh to convert into the more common BTU unit for fuels.

HRF = fraction of the waste heat from the power generation process that is recovered

- Reciprocating engine HRF = 0.5, combustion turbine HRF = 0.67 because all the waste heat is in the exhaust stream and is easier to recover (EPA 2017)
- **Assume all heat is used!** Either:
  - The CHP system is small compared to the thermal demand load.
  - Storage is sufficient to couple heat generation with heat demand.

$\eta_{\text{conv.}}$  = efficiency of conventional heating system, assumed  $\eta_{\text{conv.}} = 0.84$  for all options

fc = the cost of fuel in units of \$/kWh.

# Present Worth Factor

Future costs (O&M) and energy cost savings

Present worth factor (PWF)

The present value of annual costs or revenues during the analysis period are “escalated” according to an inflation rate,  $i$ , and then “discounted” to their present value.

$$PWF = (1+i)/(d-i) * (1 - ((1+i)/(1+d))^N)$$

$I$  = inflation rate,  $I = 0.02$  in this analysis

$D$  = discount rate,  $d = 0.03$  in this analysis

$N$  = years of analysis period,  $N = 25$  in this analysis.

The discount rate and inflation rates are specified by the National Institute of Standards and Technology (2019). From the *Annual Supplement to Handbook 135 Energy Price Indices and Discount Factors for Life Cycle Cost Analysis*, updated annually (<http://energy.gov/eere/femp/building-life-cycle-cost-programs>). Complies with 10CFR436 regulation.

Example:

$$PWF (I = 0.2\%, d = 3\%, N = 25 \text{ yr}) = 22.1 \text{ years}$$

In other words, a savings of \$1/yr for 25 years = \$22 today (net present value)

# Levelized Cost of Energy

- Levelized cost of energy (LCOE) is the annual operating cost including annualized capital cost; less savings in conventional fuels in the numerator, divided by electrical energy produced in the denominator.

$$\text{LCOE} = \{C/\text{PWF} + (C_{\text{OM}} + F * f_c)\} / P_{\text{rated}} / \text{CF}' / (8760)$$

- Here we calculate LCOE per unit of rated capacity,  $P_{\text{rated}} = 1$ .

# Sources of Data

## Energy Production

- PV: 4-km resolution, satellite data from 1998 – 2017, National Solar Radiation Database (NSRDB, <https://nsrdb.nrel.gov>); performance modeled with the System Advisor Model using PVWatts default submodule
- SHW: Annual average 10 km resolution solar resource data for a fixed flat plate system with tilt = latitude; 40% system efficiency
- CSP: 4-km resolution, satellite data from 1998 – 2017, NSRDB annual average direct normal irradiation; performance modeled with the System Advisor Model for 2 axis tracking system
- Wind: 2-km resolution wind speed at 100m hub height modeled for 2007 – 2013, WIND Toolkit (<https://www.nrel.gov/grid/wind-toolkit.html>); performance modeled with the System Advisor Model for wind turbines selected based on annual average wind speed

Annual average commercial electricity cost extracted from ABB Energy Velocity Suite and EIA State Electricity data tables

Other variables have static values, independent of location.

# Cost Assumptions for Each Technology Configuration

Case	$C_{\text{unit gen}}$ (\$/kW)	$C_{\text{unit storage}}$ (\$/kWh)	$C_{\text{unit seasonal storage}}$ (\$/kWh, thermal)	$C_{\text{O\&M gen}}$ (\$/kW/year)	$C_{\text{O\&M storage}}$ (\$/kWh/year)
PV +0-hour battery	\$ 1,783.00	\$ 380.00	\$ -	\$ 22.00	\$ 36.32
PV +4-hour battery	\$ 1,783.00	\$ 380.00	\$ -	\$ 22.00	\$ 36.32
PV +12-hour battery	\$ 1,783.00	\$ 380.00	\$ -	\$ 22.00	\$ 36.32
CSP + 0-hour TES	\$ 3,486.00	\$ 422.22	\$ -	\$ 38.89	\$ 4.71
CSP + 4-hour TES	\$ 3,486.00	\$ 422.22	\$ -	\$ 38.89	\$ 4.71
CSP + 12-hour TES	\$ 3,486.00	\$ 422.22	\$ -	\$ 38.89	\$ 4.71
Wind +0-our battery	\$ 1,624.00	\$ 380.00	\$ -	\$ 41.00	\$ 36.32
Wind +4-our battery	\$ 1,624.00	\$ 380.00	\$ -	\$ 41.00	\$ 36.32
Wind +12-hour battery	\$ 1,624.00	\$ 380.00	\$ -	\$ 41.00	\$ 36.32
Reciprocating CHP	\$ 2,200.00	\$ 48.00	\$ 1.50	\$ 83.00	\$ -
Reciprocating CHP w/seasonal storage	\$ 2,200.00	\$ 48.00	\$ 1.50	\$ 83.00	\$ -
Combustion turbine CHP	\$ 3,400.00	\$ 48.00	\$ 1.50	\$ 54.00	\$ -
Combustion turbine CHP w/seasonal storage	\$ 3,400.00	\$ 48.00	\$ 1.50	\$ 54.00	\$ -
SWH diurnal storage	\$ 1,570.00	\$ 48.00	\$ -	\$ 16.67	\$ 0.29
SWH seasonal storage	\$ 1,570.00	\$ 48.00	\$ 1.50	\$ 16.67	\$ 0.29

# Map Algebra Example

LCOE PV with 0 hours storage =

$$\frac{(1783 \text{ \$/kW}) / (22.1 \text{ years}) + (22 \text{ \$/kW-yr})}{}$$

=




kWh/kW



LCOE (\$/kWh)




## Conventional electricity:




Electricity rates are highest in California and the northeast, but also in other places such as New Mexico, and they are lowest in the northwest.




## Natural gas:




Natural gas rates are highest in the northeast, and they are lowest in the Dakotas, New Mexico, and Ohio.



CHP with combustion turbine



CHP with reciprocating engine




CHP combustion turbine  
with seasonal storage



CHP reciprocating engine  
with seasonal storage

CHP is most cost-effective where electricity rates are high and gas rates are low (spark spread), such as in the Dakotas and in Ohio but also in New Mexico.



## Photovoltaics




PV without storage



PV + 4-h storage




PV + 12-h storage



PV uses both direct and diffuse solar radiation, so the LCOE is rather uniform across the country, though it is approximately \$0.02/kWh less in the sunny southwest and approximately \$0.02 higher than average in the cloudier northeast and northwest.



## Concentrating Solar Power




CSP without storage


CSP + 4-h TES

CSP + 1- h TES


CSP can focus only direct solar radiation, so the LCOE is lowest in the desert of south-central California and in the southwest, where skies are clear and the humidity is low. The LCOE is much higher in the northeast and northwest, where solar radiation is less intense and more scattered (diffuse) because of clouds.



## Solar Water Heating




SWH with diurnal storage




SWH with seasonal storage

LCOE  
\$/kWh  
thermal



SWH systems use both direct and diffuse solar radiation, so the LCOE is rather uniform across the country; it is best in the sunny southwest, but is viable in all parts of the country.



## Wind Energy



Wind without storage




Wind + 4-h storage



Wind + 12-h storage

LCOE  
\$/kWh



Wind power is most cost-effective in the Great Plains states of North Dakota and South Dakota, Nebraska, Kansas, Oklahoma, and Texas. In general, the Rocky Mountains and Sierras present a barrier to winds, although these high-resolution data show that winds are concentrated in mountain passes, such as in southern Wyoming and several spots in California, such as Tehachapi Pass and San Gorgonio Pass, which were early locations of wind energy development.

# Thank you!

---

[www.nrel.gov](http://www.nrel.gov)

PR-77938

This work was authored in part by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by Interagency Agreement with US Army Emerging Science and Technology Commercialization Program (ESTCIP).. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.

